



疏散宽度计算值:
防火分区一: $500 \text{人} / 100 \text{m} / \text{百人} \times 0.65 = 3.25 \text{m}$
防火分区二: $500 \text{人} / 100 \text{m} / \text{百人} \times 0.65 = 3.25 \text{m}$

疏散宽度实际值: 本层建筑面积: 4397.97m^2
防火分区一: $1.8 + 2.1 \times 2 = 6 \text{m}$
防火分区二: $1.8 + 2.1 = 3.9 \text{m}$

二层平面图 1:200